



# Prüfzentrum für Bauelemente

## Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows  
 Rollläden · shutters  
 Türen + Tore · doors  
 Fassaden · curtain walling  
 Baubeschläge · building hardware

**TEST CERTIFICATE NO. 17/08-A003-Z1**

Version 1.en

PfB-Internal-No. 17/08-A371

This test certificate only certifies the specifications of the tested product and does not prejudice the specifications of similar products. The tests performed in accordance with - EN 1026 : 2000-06 "Windows and doors –Air permeability –Test method" and EN 14019 "Curtain walling –Impact resistance – performance requirements"

**Applicant** Emay Metal Kalıp Mak.Müh.Asansör San.ve Tic. Ltd.Şti.  
 Hasanağa O.S.B. HOSAB San. Cad. No:33.  
 Nilüfer - Bursa


**Product type** One leaf manual operated sliding door

**Product name** SCHMELZ HERMETIC OPERATION THEATRE DOOR

**Sealing** EPDM

**Dimension** Total outside dimensions (W x H) max. 1880 mm x 2280 mm  
 Leaf dimensions (W x H) max. 1375 mm x 2100 mm

**Classification** According to test report No. 17/08-A003-B1 from August 23, 2017:



EN 1026	Air Permeability	EN 12207	Class 3
EN 14019	Impact resistance	EN 14019	Class I0

**Validity** Period of validity of EN 14351-1: 2006 + A2 : 2016

Dipl. Ing. (FH) Rüdiger Müller  
 Head of Institute



Stephanskirchen  
 August 23, 2017

Yiğit Altuğ  
 Responsible Official